

# Inspection Certificate

*For*

Sample Building Report  
235 Main Street  
Tallmadge, OH 44278

*This Inspection was performed in accordance with applicable standards. The subsequent pages of this report provide performance measurements, listed ranges of acceptable results, and complete documentation of the inspection. Whenever discrepancies exist between acceptable performance standards and actual test results, notes and/or recommended solutions have been proposed or provided for immediate review and approval.*

*Inspection Date*  
*September 21, 2006*

Building: Sample Building Report  
Contact: John Thompson  
Title: Building Engineer

Company: County Fire Protection, Inc.  
Contact: Bob Gallagher  
Title: Account Manager

# Executive Summary

Generated by: BuildingReports.com

Building Information								
<b>Building:</b> Sample Building Report			<b>Contact:</b> John Thompson					
<b>Address:</b> 235 Main Street			<b>Phone:</b> (330) 555-1111					
<b>Address:</b>			<b>Fax:</b> (330) 555-2222					
<b>City/State/Zip:</b> Tallmadge, OH 44278			<b>Mobile:</b> (330) 555-5555					
<b>Country:</b> United States of America			<b>Email:</b> jthompson@samplebuilding.com					
Inspection Performed By								
<b>Company:</b> County Fire Protection, Inc.			<b>Inspector:</b> Bob Gallagher					
<b>Address:</b> 310 Geneva Avenue			<b>Phone:</b> (330) 633-1014					
<b>Address:</b>			<b>Fax:</b> (330) 633-2779					
<b>City/State/Zip:</b> Tallmadge, OH 44278			<b>Mobile:</b> (330) 730-8931					
<b>Country:</b> United States of America			<b>Email:</b> sales@county-fire.com					
Inspection Summary								
Category	Total Items		Serviced		Passed		Failed/Other	
	Qty	%	Qty	%	Qty	%	Qty	%
Safety	7	2%	7	100%	7	100%	0	0%
Protective	1	0%	1	100%	1	100%	0	0%
Lighting	118	35%	118	100%	118	100%	0	0%
Fire	210	63%	210	100%	184	88%	26	12%
<b>Totals</b>	<b>336</b>	<b>100%</b>	<b>336</b>	<b>100%</b>	<b>310</b>	<b>92%</b>	<b>26</b>	<b>8%</b>
Certification								
Building: Sample Building Report			Company: County Fire Protection, Inc.					
Contact: John Thompson			Inspector: Bob Gallagher					
Signed:			Signed:					

# Discrepancy Report

Generated by: [BuildingReports.com](http://BuildingReports.com)

Building: Sample Building Report				
<p><i>The Discrepancy Report consolidates each discrepancy listed within the various Testing sections of your Inspection. Discrepancies are listed by Category, and grouped by device type. The description of the problem is provided, and where appropriate, code references are listed for your convenience. Devices/items that are listed on the Consumer Product Safety Commission website for recall are provided below.</i></p>				
Device Type	Manufacturer	ModelNumber	Date	Qty
<i>Items listed for Recall by Manufacturer</i>				
No recalled items found during this inspection.				
ScanID	Location	Problem	Reference	
<i>Fire</i>				
<b>Fire Extinguisher, A.B.C, 10 Lbs</b>				
02365916	Basement Central Mechanical Room	Needs Hydro Test		
02365923	Basement Spare	Discharged	NFPA 10 1.5.2	
02365961	Basement Spare	Discharged	NFPA 10 1.5.2	
02366836	Basement Central Mechanical Room	Needs Hydro Test		
02366837	Basement Central Mechanical Room	Needs Hydro Test		
02366838	Basement Central Mechanical Room	Needs Hydro Test		
02366839	Basement Central Mechanical Room	Needs Hydro Test		
02366840	Basement Central Mechanical Room	Needs Hydro Test		
02366841	Basement Central Mechanical Room	Needs Hydro Test		
02366842	Basement Central Mechanical Room	Needs Hydro Test		
02366844	Basement Spare	Discharged	NFPA 10 1.5.2	
02366845	Basement Spare	Discharged	NFPA 10 1.5.2	
02366846	Basement Spare	Discharged	NFPA 10 1.5.2	
02365976	Basement Spare	Damaged/Worn	NFPA 10 6.2.2 (6)	
02365977	Basement Spare	Needs Hydro Test		
02366848	Basement Employee Break Room	Damaged/Worn	NFPA 10 6.2.2 (6)	
02366847	1st Behind Security Desk	Damaged/Worn	NFPA 10 6.2.2 (6)	
02365966	2nd North Elevator Lobby	Needs 6yr Maintenance		
02365967	2nd South Elevator Lobby	Needs 6yr Maintenance		
02365962	3rd Cafeteria	Needs Hydro Test		
02365963	3rd Atrium Hallway	Needs 6yr Maintenance		
02365973	4th Audio/Visual Storeroom	Needs 6yr Maintenance		
02365974	4th Hallway Break Area	Needs 6yr Maintenance		
02366002	7th West Hallway	Damaged/Worn	NFPA 10 6.2.2 (6)	
02365957	10th West Hallway	Needs 6yr Maintenance		
02365956	Penthouse Elevator Equipment Room	Needs 6yr Maintenance		
<i>Code References</i>				

🔑 ScanID	📍 Location	🔑 Problem	📖 Reference
NFPA 10 1.5.2		Portable fire extinguishers shall be maintained in a fully charged and operable condition and shall be kept in their designated places at all times when they are not being used.	
NFPA 10 6.2.2 (6)		When an inspection of any fire extinguisher reveals a deficiency in any of the conditions listed in 6.2.2, immediate corrective action shall be taken.	
		6.2.2 (6) Examination for obvious physical damage, corrosion, leakage, or clogged nozzle.	

# Proposed Solutions Report

Generated by: BuildingReports.com

<b>Building: Sample Building Report</b>
---

*The Proposed Solution Report provides a solution for each discrepancy listed on the Discrepancy Report. Provide a check mark where indicated to approve repairs listed within the report. Items listed as T/M are available for repair on a Time and Materials basis.*

ScanID	Location	Solution	Cost	Fix
<b><i>Fire</i></b>				
<b>Fire Extinguisher, A.B.C, 10 Lbs</b>				
02365916	Basement Central Mechanical Room	Schedule Service	T/M	<input type="checkbox"/>
02365923	Basement Spare	Schedule Service	T/M	<input type="checkbox"/>
02365961	Basement Spare	Schedule Service	T/M	<input type="checkbox"/>
02366836	Basement Central Mechanical Room	Schedule Service	T/M	<input type="checkbox"/>
02366837	Basement Central Mechanical Room	Schedule Service	T/M	<input type="checkbox"/>
02366838	Basement Central Mechanical Room	Schedule Service	T/M	<input type="checkbox"/>
02366839	Basement Central Mechanical Room	Schedule Service	T/M	<input type="checkbox"/>
02366840	Basement Central Mechanical Room	Schedule Service	T/M	<input type="checkbox"/>
02366841	Basement Central Mechanical Room	Schedule Service	T/M	<input type="checkbox"/>
02366842	Basement Central Mechanical Room	Schedule Service	T/M	<input type="checkbox"/>
02366844	Basement Spare	Schedule Service	T/M	<input type="checkbox"/>
02366845	Basement Spare	Schedule Service	T/M	<input type="checkbox"/>
02366846	Basement Spare	Schedule Service	T/M	<input type="checkbox"/>
02365976	Basement Spare	Notify Maintenance	T/M	<input type="checkbox"/>
02365977	Basement Spare	Schedule Service	T/M	<input type="checkbox"/>
02366848	Basement Employee Break Room	Notify Maintenance	T/M	<input type="checkbox"/>
02366847	1st Behind Security Desk	Notify Maintenance	T/M	<input type="checkbox"/>
02365966	2nd North Elevator Lobby	Schedule Service	T/M	<input type="checkbox"/>
02365967	2nd South Elevator Lobby	Schedule Service	T/M	<input type="checkbox"/>
02365962	3rd Cafeteria	Schedule Service	T/M	<input type="checkbox"/>
02365963	3rd Atrium Hallway	Schedule Service	T/M	<input type="checkbox"/>
02365973	4th Audio/Visual Storeroom	Schedule Service	T/M	<input type="checkbox"/>
02365974	4th Hallway Break Area	Schedule Service	T/M	<input type="checkbox"/>
02366002	7th West Hallway	Schedule Service	T/M	<input type="checkbox"/>
02365957	10th West Hallway	Schedule Service	T/M	<input type="checkbox"/>
02365956	Penthouse Elevator Equipment Room	Schedule Service	T/M	<input type="checkbox"/>

# Notes & Recommendations

Generated by: BuildingReports.com

## Building: Sample Building Report

The Notes & Recommendations Report details additional inspection notes made by the Inspectors during the course of the building inspection. Notes are grouped by Category.

Note	Device Type	Location	Comment	ScanID
<b><i>Fire</i></b>				
1	Fire Extinguisher	Basement Spare	Discharged	02365923
Device has been vandalized but still functions ok, needs servicing				
<b><i>Protective</i></b>				
2	Hearing Protection	Basement Central Mechanical Room		02366710
Box of 100; 83 pairs remaining				

# Inspection & Testing

Generated by: [BuildingReports.com](http://BuildingReports.com)

<b>Building: Sample Building Report</b>
---

*The Inspection & Testing section lists all of the items inspected in your building. Items are grouped by Passed or Failed/Other. Items are listed by Category. Each item includes the services performed, and the time & date at which testing occurred. For more information about an item, click on the link provided.*

Device Type	Location	ScanID : S/N	Service	Date Time
<b><i>Passed</i></b>				
<b>Fire</b>				
Extinguisher Cabinet, Hammer: No	1st East Hallway	02366660	Inspect	09/20/06 6:39:50 AM
Extinguisher Cabinet, Hammer: No	1st West Hallway	02366659	Inspect	09/20/06 6:39:48 AM
Extinguisher Cabinet, Hammer: No	2nd East Hallway	02366657	Inspect	09/20/06 6:39:02 AM
Extinguisher Cabinet, Hammer: No	2nd West Hallway	02366658	Inspect	09/21/06 11:25:43 AM
Extinguisher Cabinet, Hammer: No	3rd East Hallway	02366656	Inspect	09/20/06 6:38:59 AM
Extinguisher Cabinet, Hammer: No	3rd West Hallway	02366655	Inspect	09/20/06 6:38:32 AM
Extinguisher Cabinet, Hammer: No	4th East Hallway	02366653	Inspect	09/20/06 6:37:18 AM
Extinguisher Cabinet, Hammer: No	4th West Hallway	02366654	Inspect	09/20/06 6:38:12 AM
Extinguisher Cabinet, Hammer: No	5th East Hallway	02366652	Inspect	09/20/06 6:36:40 AM
Extinguisher Cabinet, Hammer: No	5th West Hallway	02366651	Inspect	09/20/06 6:36:27 AM
Extinguisher Cabinet, Hammer: No	6th East Hallway	02366649	Inspect	09/20/06 6:32:25 AM
Extinguisher Cabinet, Hammer: No	6th West Hallway	02366650	Inspect	09/20/06 6:36:18 AM
Extinguisher Cabinet, Hammer: No	7th East Hallway	02366648	Inspect	09/20/06 6:32:10 AM
Extinguisher Cabinet, Hammer: No	7th West Hallway	02366647	Inspect	09/20/06 6:31:53 AM
Extinguisher Cabinet, Hammer: No	8th East Hallway	02366645	Inspect	09/20/06 6:31:14 AM
Extinguisher Cabinet, Hammer: No	8th West Hallway	02366646	Inspect	09/20/06 6:31:29 AM
Extinguisher Cabinet, Hammer: No	9th East Hallway	02366644	Inspect	09/20/06 6:31:04 AM
Extinguisher Cabinet, Hammer: No	9th West Hallway	02366643	Inspect	09/20/06 6:30:36 AM
Extinguisher Cabinet, Hammer: No	10th East Hallway	02366641	Inspect	09/20/06 6:24:41 AM
Extinguisher Cabinet, Hammer: No	10th West Hallway	02366642	Inspect	09/20/06 6:24:51 AM

Device Type	Location	ScanID : S/N	Service	Date Time
Hammer: No				
Fire Damper, Smoke	Basement Elevator Pit	02366624	Inspect	09/20/06 3:42:06 PM
Fire Damper, Smoke	Basement Central Mechanical Room	02366601	Inspect	09/20/06 3:35:35 PM
Fire Damper, Smoke	1st Elevator Shaft	02366623	Inspect	09/20/06 3:41:42 PM
Fire Damper, Smoke	1st Mechanical Room	02366612	Inspect	09/20/06 3:38:03 PM
Fire Damper, Smoke	2nd Elevator Shaft	02366622	Inspect	09/20/06 3:41:27 PM
Fire Damper, Smoke	2nd Mechanical Room	02366611	Inspect	09/20/06 3:37:54 PM
Fire Damper, Smoke	3rd Elevator Shaft	02366621	Inspect	09/20/06 3:41:17 PM
Fire Damper, Smoke	3rd Mechanical Room	02366610	Inspect	09/20/06 3:37:43 PM
Fire Damper, Smoke	4th Elevator Shaft	02366620	Inspect	09/20/06 3:41:08 PM
Fire Damper, Smoke	4th Mechanical Room	02366609	Inspect	09/20/06 3:37:40 PM
Fire Damper, Smoke	5th Elevator Shaft	02366619	Inspect	09/20/06 3:40:30 PM
Fire Damper, Smoke	5th Mechanical Room	02366608	Inspect	09/20/06 3:37:22 PM
Fire Damper, Smoke	6th Elevator Shaft	02366618	Inspect	09/20/06 3:40:14 PM
Fire Damper, Smoke	6th Mechanical Room	02366607	Inspect	09/20/06 3:36:54 PM
Fire Damper, Smoke	7th Elevator Shaft	02366617	Inspect	09/20/06 3:40:00 PM
Fire Damper, Smoke	7th Mechanical Room	02366606	Inspect	09/20/06 3:36:39 PM
Fire Damper, Smoke	8th Elevator Shaft	02366616	Inspect	09/20/06 3:39:41 PM
Fire Damper, Smoke	8th Mechanical Room	02366605	Inspect	09/20/06 3:36:27 PM
Fire Damper, Smoke	9th Elevator Shaft	02366615	Inspect	09/20/06 3:39:29 PM
Fire Damper, Smoke	9th Mechanical Room	02366604	Inspect	09/20/06 3:36:13 PM
Fire Damper, Smoke	10th Elevator Shaft	02366614	Inspect	09/20/06 3:39:15 PM
Fire Damper, Smoke	10th Mechanical Room	02366603	Inspect	09/20/06 3:36:04 PM
Fire Damper, Smoke	Penthouse Elevator Shaft	02366613	Inspect	09/20/06 3:38:38 PM
Fire Damper, Smoke	Penthouse Mechanical Room	02366602	Inspect	09/20/06 3:35:24 PM
Fire Door, 4.0, Automatic Closing	Basement East Elevator Lobby	02366640	Inspect	09/20/06 6:24:21APM
Fire Door, 4.0, Automatic Closing	Basement West Elevator Lobby	02366639	Inspect	09/20/06 5:16:43 PM
Fire Door, 4.0, Automatic Closing	4th East Elevator Lobby	02366637	Inspect	09/20/06 5:16:18 PM
Fire Door, 4.0, Automatic Closing	4th West Elevator Lobby	02366638	Inspect	09/20/06 5:16:28 PM
Fire Door, 4.0, Automatic Closing	5th East Elevator Lobby	02366636	Inspect	09/20/06 5:16:06 PM
Fire Door, 4.0, Automatic Closing	5th West Elevator Lobby	02366635	Inspect	09/20/06 5:15:53 PM
Fire Door, 4.0, Automatic Closing	6th East Elevator Lobby	02366633	Inspect	09/20/06 5:15:19 PM
Fire Door, 4.0, Automatic Closing	6th West Elevator Lobby	02366634	Inspect	09/20/06 5:15:43 PM
Fire Door, 4.0, Automatic Closing	7th East Elevator Lobby	02366632	Inspect	09/20/06 3:52:07 PM
Fire Door, 4.0, Automatic Closing	7th West Elevator Lobby	02366631	Inspect	09/20/06 3:51:57 PM
Fire Door, 4.0, Automatic Closing	8th East Elevator Lobby	02366629	Inspect	09/20/06 3:51:26 PM
Fire Door, 4.0, Automatic Closing	8th West Elevator Lobby	02366630	Inspect	09/20/06 3:51:45 PM
Fire Door, 4.0, Automatic Closing	9th East Elevator Lobby	02366628	Inspect	09/20/06 3:51:15 PM



Device Type	Location	ScanID : S/N	Service	Date Time
Fire Door, 4.0, Automatic Closing	9th West Elevator Lobby	02366627	Inspect	09/20/06 3:51:02 PM
Fire Door, 4.0, Automatic Closing	10th East Elevator Lobby	02366625	Inspect	09/20/06 3:43:30 PM
Fire Door, 4.0, Automatic Closing	10th West Elevator Lobby	02366626	Inspect	09/20/06 3:50:32 PM
Fire Extinguisher, 5 Lbs, A.B.C	Basement Engineering Office	02365978 : GA-025204	Checked	09/21/06 4:45:27 PM
Fire Extinguisher, 10 Lbs, A.B.C	Basement Fire Control Center	02365920 : SH-035672	Checked	09/21/06 9:57:12 AM
Fire Extinguisher, 10 Lbs, A.B.C	Basement Fire Control Center	02365922 : NC-595067	Checked	09/21/06 10:10:12 AM
Fire Extinguisher, 10 Lbs, A.B.C	Basement Fire Control Center	02365925 : JD-933054	Checked	09/21/06 10:28:12 AM
Fire Extinguisher, 10 Lbs, A.B.C	Basement Fire Control Center	02365921 : MZ-595183	Checked	09/21/06 8:28:21 AM
Fire Extinguisher, 10 Lbs, A.B.C	Basement Health Spa	02365924 : JL-515935	Checked	09/21/06 10:22:19 AM
Fire Extinguisher, 10 Lbs, A.B.C	Basement Mechanical Room	02365989 : HT-768248	Checked	09/21/06 9:02:47 AM
Fire Extinguisher, 10 Lbs, A.B.C	Basement Service Elevator Lobby	02365945 : HT-768248	Checked	09/21/06 1:28:12 PM
Fire Extinguisher, 13 Lbs, Halon	Basement Storeroom Spare	02365951 : U-227909	Checked	09/21/06 2:06:10 PM
Fire Extinguisher, 13 Lbs, Halon	Basement Storeroom Spare	02365952 : U-227907	Checked	09/21/06 2:10:13 PM
Fire Extinguisher, 10 Lbs, A.B.C.	Basement Storeroom Spare	02365953 : RP-563900	Checked	09/21/06 3:00:33 PM
Fire Extinguisher, 10 Lbs, A.B.C.	Basement Storeroom Spare	02365954 : RP-564924	Checked	09/21/06 3:01:31 PM
Fire Extinguisher, 10 Lbs, A.B.C	Basement Telephone/Electrical Room	02365981 : HT-768248	Checked	09/21/06 5:10:21 PM
Fire Extinguisher, 10 Lbs, A.B.C	Basement Telephone/Electrical Room	02365918 : NM-451726	Checked	09/21/06 3:38:34 PM
Fire Extinguisher, 10 Lbs, A.B.C	Basement Central Mechanical Room	02365917 : MR-917697	Checked	09/21/06 8:30:13 AM
Fire Extinguisher, 10 Lbs, A.B.C	Basement Emergency Generator Room	02365919 : EF-098174	Checked	09/21/06 8:29:08 AM
Fire Extinguisher, 10 Lbs, A.B.C	1st Bank Entrance	02365975 : ET-264732	Checked	09/21/06 4:28:11 PM
Fire Extinguisher, 10 Lbs, A.B.C	1st Mechanical Room	02365990 : HT-768248	Checked	09/21/06 10:01:27 AM
Fire Extinguisher, 10 Lbs, A.B.C	1st Security Console	02365972 : HT-727126	Checked	09/21/06 4:10:10 PM
Fire Extinguisher, 10 Lbs, A.B.C	1st Service Elevator Lobby	02365944 : HT-768248	Checked	09/21/06 1:22:13 PM
Fire Extinguisher, 10 Lbs, A.B.C	1st Service Hallway	02365969 : HT-768248	Checked	09/21/06 3:51:11 PM
Fire Extinguisher, 10 Lbs, A.B.C	1st Telephone/Electrical Room	02365980 : HT-768248	Checked	09/21/06 5:06:21 PM
Fire Extinguisher, 10 Lbs, A.B.C	1st East Hallway At Stairs	02365968 : FT-325226	Checked	09/21/06 3:46:12 PM

Device Type	Location	ScanID : S/N	Service	Date Time
Fire Extinguisher, 10 Lbs, A.B.C	1st North Elevator Hallway	02365971 : HT-767209	Checked	09/21/06 4:06:10 PM
Fire Extinguisher, 10 Lbs, A.B.C	1st South Elevator Hallway	02365965 : FV-120170	Checked	09/21/06 3:28:13 PM
Fire Extinguisher, 10 Lbs, A.B.C	1st West Hallway At Stairs	02365970 : GA-258291	Checked	09/21/06 3:57:10 PM
Fire Extinguisher, 10 Lbs, A.B.C	2nd Mechanical Room	02365991 : HT-768248	Checked	09/21/06 11:02:27 AM
Fire Extinguisher, 10 Lbs, A.B.C	2nd Service Elevator Lobby	02365943 : HT-768248	Checked	09/21/06 1:16:10 PM
Fire Extinguisher, 10 Lbs, A.B.C	2nd Telephone/Electrical Room	02365979 : HT-768248	Checked	09/21/06 4:59:37 PM
Fire Extinguisher, 10 Lbs, A.B.C	2nd East Hallway	02365992 : HT-768248	Checked	09/21/06 11:28:56 AM
Fire Extinguisher, 10 Lbs, A.B.C	2nd West Hallway	02365993 : HT-768248	Checked	09/21/06 12:03:23 PM
Fire Extinguisher, 10 Lbs, A.B.C	3rd Conference Cntr	02365926 : MC-00068157	Checked	09/21/06 10:34:15 AM
Fire Extinguisher, 6 Ltr, Class K	3rd Kitchen	02365955 : AA-534308	Checked	09/21/06 2:28:09 PM
Fire Extinguisher, 10 Lbs, A.B.C	3rd Mechanical Room	02365988 : HT-768248	Checked	09/21/06 5:51:25 PM
Fire Extinguisher, 10 Lbs, A.B.C	3rd Service Elevator Lobby	02365942 : HT-768248	Checked	09/21/06 1:10:12 PM
Fire Extinguisher, 5 Lbs, A.B.C	3rd Service Hallway	02365927 : KG-00225502	Checked	09/21/06 10:40:13 AM
Fire Extinguisher, 10 Lbs, A.B.C	3rd Telephone/Electrical Room	02365964 : HT-768248	Checked	09/21/06 3:22:13 PM
Fire Extinguisher, 10 Lbs, A.B.C	3rd East Hallway	02365994 : HT-768248	Checked	09/21/06 12:09:38 PM
Fire Extinguisher, 10 Lbs, A.B.C	3rd West Hallway	02365995 : HT-768248	Checked	09/21/06 12:15:44 PM
Fire Extinguisher, 10 Lbs, A.B.C	4th Mechanical Room	02365987 : HT-768248	Checked	09/21/06 5:45:31 PM
Fire Extinguisher, 10 Lbs, A.B.C	4th Service Elevator Lobby	02365941 : HT-768248	Checked	09/21/06 1:06:12 PM
Fire Extinguisher, 10 Lbs, A.B.C	4th Telephone/Electrical Room	02365950 : HT-768248	Checked	09/21/06 1:56:18 PM
Fire Extinguisher, 10 Lbs, A.B.C	4th East Hallway	02365996 : HT-768248	Checked	09/21/06 4:03:03 PM
Fire Extinguisher, 10 Lbs, A.B.C	4th West Hallway	02366005 : HT-768248	Checked	09/21/06 6:03:17 PM
Fire Extinguisher, 10 Lbs, A.B.C	5th Mechanical Room	02365985 : HT-768248	Checked	09/21/06 5:34:20 PM
Fire Extinguisher, 10 Lbs, A.B.C	5th Service Elevator Lobby	02365940 : HT-768248	Checked	09/21/06 12:58:30 PM
Fire Extinguisher, 10 Lbs, A.B.C	5th Telephone/Electrical Room	02365949 : HT-768248	Checked	09/21/06 1:51:07 PM
Fire Extinguisher, 10 Lbs, A.B.C	5th East Hallway	02365998 : HT-768248	Checked	09/21/06 5:39:23 PM
Fire Extinguisher, 10 Lbs, A.B.C	5th West Hallway	02365999 : HT-768248	Checked	09/21/06 5:57:24 PM

Device Type	Location	ScanID : S/N	Service	Date Time
Fire Extinguisher, 10 Lbs, A.B.C	6th Mechanical Room	02365984 : HT-768248	Checked	09/21/06 5:28:18 PM
Fire Extinguisher, 10 Lbs, A.B.C	6th Service Elevator Lobby	02365939 : HT-768248	Checked	09/21/06 11:57:13 AM
Fire Extinguisher, 10 Lbs, A.B.C	6th Telephone/Electrical Room	02365948 : HT-768248	Checked	09/21/06 1:45:15 PM
Fire Extinguisher, 10 Lbs, A.B.C	6th East Hallway	02365997 : HT-768248	Checked	09/21/06 4:51:24 PM
Fire Extinguisher, 10 Lbs, A.B.C	6th West Hallway	02366000 : HT-768248	Checked	09/21/06 12:21:36 PM
Fire Extinguisher, 10 Lbs, A.B.C	7th Mechanical Room	02365983 : HT-768248	Checked	09/21/06 5:22:21 PM
Fire Extinguisher, 10 Lbs, A.B.C	7th Service Elevator Lobby	02365938 : HT-768248	Checked	09/21/06 11:51:13 AM
Fire Extinguisher, 10 Lbs, A.B.C	7th Telephone/Electrical Room	02365947 : HT-768248	Checked	09/21/06 1:40:39 PM
Fire Extinguisher, 10 Lbs, A.B.C	7th East Hallway	02366001 : HT-768248	Checked	09/21/06 12:27:20 PM
Fire Extinguisher, 10 Lbs, A.B.C	8th Mechanical Room	02365982 : HT-768248	Checked	09/21/06 5:16:17 PM
Fire Extinguisher, 10 Lbs, A.B.C	8th Service Elevator Lobby	02365937 : HT-768248	Checked	09/21/06 11:45:12 AM
Fire Extinguisher, 10 Lbs, A.B.C	8th Telephone/Electrical Room	02365946 : HT-768248	Checked	09/21/06 1:35:13 PM
Fire Extinguisher, 10 Lbs, A.B.C	8th East Hallway	02366003 : HT-768248	Checked	09/21/06 12:39:23 PM
Fire Extinguisher, 10 Lbs, A.B.C	8th West Hallway	02366004 : HT-768248	Checked	09/21/06 12:45:39 PM
Fire Extinguisher, 10 Lbs, A.B.C	9th Mechanical Room	02365935 : HT-768248	Checked	09/21/06 11:34:09 AM
Fire Extinguisher, 10 Lbs, A.B.C	9th Service Elevator Lobby	02365936 : HT-768248	Checked	09/21/06 11:40:10 AM
Fire Extinguisher, 10 Lbs, A.B.C	9th Telephone/Electrical Room	02365934 : HT-768248	Checked	09/21/06 11:22:12 AM
Fire Extinguisher, 10 Lbs, A.B.C	9th East Hallway	02365932 : HT-768248	Checked	09/21/06 11:10:11 AM
Fire Extinguisher, 10 Lbs, A.B.C	9th West Hallway	02365933 : HT-768248	Checked	09/21/06 11:16:17 AM
Fire Extinguisher, 10 Lbs, A.B.C	10th Mechanical Room	02365930 : HT-768248	Checked	09/21/06 10:57:12 AM
Fire Extinguisher, 10 Lbs, A.B.C	10th Service Elevator Lobby	02365929 : HT-768248	Checked	09/21/06 10:51:21 AM
Fire Extinguisher, 10 Lbs, A.B.C	10th Telephone/Electrical Room	02365931 : HT-768248	Checked	09/21/06 11:06:12 AM
Fire Extinguisher, 10 Lbs, A.B.C	10th East Hallway	02365928 : HT-768248	Checked	09/21/06 10:45:17 AM
Fire Extinguisher, 10 Lbs, A.B.C	Penthouse Mechanical Room	02365958 : HT-768248	Checked	09/21/06 2:45:13 PM
Fire Extinguisher, 10 Lbs, A.B.C	Penthouse Service Elevator Lobby	02365959 : HT-768248	Checked	09/21/06 2:51:12 PM
Fire Extinguisher, 10 Lbs, A.B.C	Penthouse Telephone/Electrical Room	02365960 : HT-768248	Checked	09/21/06 2:59:11 PM

Device Type	Location	ScanID : S/N	Service	Date Time
Fire Hose, 50 ft, Dual Jacket, 2 1/2 Dia.	Basement East Hallway	02366683	Inspect	09/20/06 6:53:47 AM
Fire Hose, 50 ft, Dual Jacket, 2 1/2 Dia.	Basement West Hallway	02366684	Inspect	09/20/06 6:53:56 AM
Fire Hose, 50 ft, Dual Jacket, 2 1/2 Dia.	1st East Hallway	02366682	Inspect	09/20/06 6:53:37 AM
Fire Hose, 50 ft, Dual Jacket, 2 1/2 Dia.	1st West Hallway	02366681	Inspect	09/20/06 6:53:24 AM
Fire Hose, 50 ft, Dual Jacket, 2 1/2 Dia.	2nd East Hallway	02366679	Inspect	09/20/06 6:51:58 AM
Fire Hose, 50 ft, Dual Jacket, 2 1/2 Dia.	2nd West Hallway	02366680	Inspect	09/20/06 6:53:08 AM
Fire Hose, 50 ft, Dual Jacket, 2 1/2 Dia.	3rd East Hallway	02366677	Inspect	09/20/06 6:51:24 AM
Fire Hose, 50 ft, Dual Jacket, 2 1/2 Dia.	3rd West Hallway	02366678	Inspect	09/21/06 9:06:52 AM
Fire Hose, 50 ft, Dual Jacket, 2 1/2 Dia.	4th East Hallway	02366676	Inspect	09/20/06 6:51:13 AM
Fire Hose, 50 ft, Dual Jacket, 2 1/2 Dia.	4th West Hallway	02366675	Inspect	09/20/06 6:51:05 AM
Fire Hose, 50 ft, Dual Jacket, 2 1/2 Dia.	5th East Hallway	02366673	Inspect	09/20/06 6:50:42 AM
Fire Hose, 50 ft, Dual Jacket, 2 1/2 Dia.	5th West Hallway	02366674	Inspect	09/20/06 6:50:52 AM
Fire Hose, 50 ft, Dual Jacket, 2 1/2 Dia.	6th East Hallway	02366672	Inspect	09/20/06 6:50:34 AM
Fire Hose, 50 ft, Dual Jacket, 2 1/2 Dia.	6th West Hallway	02366671	Inspect	09/20/06 6:50:02 AM
Fire Hose, 50 ft, Dual Jacket, 2 1/2 Dia.	7th East Hallway	02366669	Inspect	09/20/06 6:49:39 AM
Fire Hose, 50 ft, Dual Jacket, 2 1/2 Dia.	7th West Hallway	02366670	Inspect	09/20/06 6:49:50 AM
Fire Hose, 50 ft, Dual Jacket, 2 1/2 Dia.	8th East Hallway	02366668	Inspect	09/20/06 6:49:28 AM
Fire Hose, 50 ft, Dual Jacket, 2 1/2 Dia.	8th West Hallway	02366667	Inspect	09/20/06 6:49:14 AM
Fire Hose, 50 ft, Dual Jacket, 2 1/2 Dia.	9th East Hallway	02366665	Inspect	09/20/06 6:48:31 AM
Fire Hose, 50 ft, Dual Jacket, 2 1/2 Dia.	9th West Hallway	02366666	Inspect	09/20/06 6:48:43 AM
Fire Hose, 50 ft, Dual Jacket, 2 1/2 Dia.	10th East Hallway	02366664	Inspect	09/20/06 6:48:13 AM
Fire Hose, 50 ft, Dual Jacket, 2 1/2 Dia.	10th West Hallway	02366663	Inspect	09/20/06 6:47:59 AM
Fire Hose, 50 ft, Dual Jacket, 2 1/2 Dia.	Penthouse East Hallway	02366661	Inspect	09/20/06 6:44:22 AM
Fire Hose, 50 ft, Dual Jacket, 2 1/2 Dia.	Penthouse West Hallway	02366662	Inspect	09/20/06 6:46:56 AM
Fire Hose Cabinet, 50 ft, Dual Jacket	Basement East Hallway	02366708	Inspect	09/20/06 7:03:41 AM
Fire Hose Cabinet, 50 ft, Dual Jacket	Basement West Hallway	02366707	Inspect	09/20/06 7:03:16 AM

Device Type	Location	ScanID : S/N	Service	Date Time
Fire Hose Cabinet, 50 ft, Dual Jacket	1st East Hallway	02366705	Inspect	09/20/06 7:02:44 AM
Fire Hose Cabinet, 50 ft, Dual Jacket	1st West Hallway	02366706	Inspect	09/20/06 7:02:54 AM
Fire Hose Cabinet, 50 ft, Dual Jacket	2nd East Hallway	02366704	Inspect	09/20/06 7:02:22 AM
Fire Hose Cabinet, 50 ft, Dual Jacket	2nd West Hallway	02366703	Inspect	09/20/06 7:02:12 AM
Fire Hose Cabinet, 50 ft, Dual Jacket	3rd East Hallway	02366701	Inspect	09/20/06 7:01:52 AM
Fire Hose Cabinet, 50 ft, Dual Jacket	3rd West Hallway	02366702	Inspect	09/20/06 7:02:01 AM
Fire Hose Cabinet, 50 ft, Dual Jacket	4th East Hallway	02366700	Inspect	09/20/06 7:01:37 AM
Fire Hose Cabinet, 50 ft, Dual Jacket	4th West Hallway	02366699	Inspect	09/20/06 7:01:26 AM
Fire Hose Cabinet, 50 ft, Dual Jacket	5th East Hallway	02366697	Inspect	09/20/06 7:01:06 AM
Fire Hose Cabinet, 50 ft, Dual Jacket	5th West Hallway	02366698	Inspect	09/20/06 7:01:15 AM
Fire Hose Cabinet, 50 ft, Dual Jacket	6th East Hallway	02366696	Inspect	09/20/06 7:00:55 AM
Fire Hose Cabinet, 50 ft, Dual Jacket	6th West Hallway	02366695	Inspect	09/20/06 7:00:36 AM
Fire Hose Cabinet, 50 ft, Dual Jacket	7th East Hallway	02366693	Inspect	09/20/06 6:59:40 AM
Fire Hose Cabinet, 50 ft, Dual Jacket	7th West Hallway	02366694	Inspect	09/20/06 6:59:58 AM
Fire Hose Cabinet	8th East Hallway	02366692	Inspect	09/21/06 9:08:45 AM
Fire Hose Cabinet, 50 ft, Dual Jacket	8th West Hallway	02366691	Inspect	09/20/06 6:59:16 AM
Fire Hose Cabinet	9th East Hallway	02366689	Inspect	09/21/06 9:07:42 AM
Fire Hose Cabinet, 50 ft, Dual Jacket	9th West Hallway	02366690	Inspect	09/20/06 6:58:27 AM
Fire Hose Cabinet, 50 ft, Dual Jacket	10th East Hallway	02366687	Inspect	09/20/06 6:57:07 AM
Fire Hose Cabinet, 50 ft, Dual Jacket	10th West Hallway	02366688	Inspect	09/20/06 6:57:57 AM
Fire Hose Cabinet, 50 ft, Dual Jacket	Penthouse East Hallway	02366686	Inspect	09/20/06 6:56:49 AM
Fire Hose Cabinet, 50 ft, Dual Jacket	Penthouse West Hallway	02366685	Inspect	09/20/06 6:55:59 AM
Wheeled Unit	Basement Center Equipment Room	02366709	Inspect	09/20/06 7:04:46 AM
<b>Lighting</b>				
Emergency Generator, Diesel	Basement Outside Chiller Room	02366718	Inspect	09/21/06 7:39:26 AM
Emergency Light, Dual Head Remote	Basement Chiller Room	02366744	Inspect	09/20/06 8:45:15 AM
Emergency Light, Dual Head Remote	Basement Generator Area	02366745	Inspect	09/20/06 8:45:48 AM
Emergency Light, Dual	Basement Loading Dock	02366743	Inspect	09/20/06 8:44:41 AM

Device Type	Location	ScanID : S/N	Service	Date Time
Head Remote				
Emergency Light, Dual	Basement East Stairwell	02366741	Inspect	09/20/06 8:43:59 AM
Head Remote				
Emergency Light, Dual	Basement North Lobby	02366769	Inspect	09/21/06 8:30:59 AM
Head Remote				
Emergency Light, Dual	Basement South Lobby	02366768	Inspect	09/21/06 8:25:30 AM
Head Remote				
Emergency Light, Dual	Basement West Stairwell	02366742	Inspect	09/20/06 8:44:29 AM
Head Remote				
Emergency Light, Dual	1st East Stairwell	02366740	Inspect	09/20/06 8:41:46 AM
Head Remote				
Emergency Light, Dual	1st North Lobby	02366766	Inspect	09/21/06 8:24:38 AM
Head Remote				
Emergency Light, Dual	1st South Lobby	02366767	Inspect	09/21/06 8:25:15 AM
Head Remote				
Emergency Light, Dual	1st West Stairwell	02366739	Inspect	09/20/06 8:39:48 AM
Head Remote				
Emergency Light, Dual	2nd East Stairwell	02366737	Inspect	09/20/06 8:39:16 AM
Head Remote				
Emergency Light, Dual	2nd North Corridor	02366765	Inspect	09/21/06 8:24:13 AM
Head Remote				
Emergency Light, Dual	2nd South Corridor	02366764	Inspect	09/21/06 8:23:47 AM
Head Remote				
Emergency Light, Dual	2nd West Stairwell	02366738	Inspect	09/20/06 8:39:27 AM
Head Remote				
Emergency Light, Dual	3rd East Stairwell	02366736	Inspect	09/20/06 8:39:06 AM
Head Remote				
Emergency Light, Dual	3rd North Corridor	02366762	Inspect	09/21/06 8:23:25 AM
Head Remote				
Emergency Light, Dual	3rd South Corridor	02366763	Inspect	09/21/06 8:23:35 AM
Head Remote				
Emergency Light, Dual	3rd West Stairwell	02366735	Inspect	09/20/06 8:38:58 AM
Head Remote				
Emergency Light, Dual	4th East Stairwell	02366733	Inspect	09/20/06 8:38:37 AM
Head Remote				
Emergency Light, Dual	4th North Corridor	02366761	Inspect	09/21/06 8:23:07 AM
Head Remote				
Emergency Light, Dual	4th South Corridor	02366760	Inspect	09/21/06 8:22:56 AM
Head Remote				
Emergency Light, Dual	4th West Stairwell	02366734	Inspect	09/20/06 8:38:46 AM
Head Remote				
Emergency Light, Dual	5th East Stairwell	02366732	Inspect	09/20/06 8:38:28 AM
Head Remote				
Emergency Light, Dual	5th North Corridor	02366758	Inspect	09/21/06 8:22:33 AM
Head Remote				
Emergency Light, Dual	5th South Corridor	02366759	Inspect	09/21/06 8:22:43 AM
Head Remote				
Emergency Light, Dual	5th West Stairwell	02366731	Inspect	09/20/06 8:38:19 AM
Head Remote				
Emergency Light, Dual	6th East Stairwell	02366729	Inspect	09/20/06 8:37:59 AM
Head Remote				
Emergency Light, Dual	6th North Corridor	02366757	Inspect	09/21/06 8:08:00 AM

Device Type	Location	ScanID : S/N	Service	Date Time
Head Remote				
Emergency Light, Dual	6th South Corridor	02366756	Inspect	09/21/06 8:22:09 AM
Head Remote				
Emergency Light, Dual	6th West Stairwell	02366730	Inspect	09/20/06 8:38:11 AM
Head Remote				
Emergency Light, Dual	7th East Stairwell	02366728	Inspect	09/20/06 8:37:49 AM
Head Remote				
Emergency Light, Dual	7th North Corridor	02366754	Inspect	09/21/06 8:21:35 AM
Head Remote				
Emergency Light, Dual	7th South Corridor	02366755	Inspect	09/21/06 8:21:55 AM
Head Remote				
Emergency Light, Dual	7th West Stairwell	02366727	Inspect	09/20/06 8:37:30 AM
Head Remote				
Emergency Light, Dual	8th East Stairwell	02366725	Inspect	09/20/06 8:36:50 AM
Head Remote				
Emergency Light, Dual	8th North Corridor	02366753	Inspect	09/21/06 8:21:18 AM
Head Remote				
Emergency Light, Dual	8th South Corridor	02366752	Inspect	09/21/06 8:20:09 AM
Head Remote				
Emergency Light, Dual	8th West Stairwell	02366726	Inspect	09/20/06 8:37:15 AM
Head Remote				
Emergency Light, Dual	9th East Stairwell	02366724	Inspect	09/20/06 8:36:38 AM
Head Remote				
Emergency Light, Dual	9th North Corridor	02366750	Inspect	09/20/06 9:22:27 AM
Head Remote				
Emergency Light, Dual	9th South Corridor	02366751	Inspect	09/21/06 8:19:38 AM
Head Remote				
Emergency Light, Dual	9th West Stairwell	02366723	Inspect	09/20/06 8:36:16 AM
Head Remote				
Emergency Light, Dual	10th East Stairwell	02366721	Inspect	09/20/06 8:34:20 AM
Head Remote				
Emergency Light, Dual	10th North Corridor	02366749	Inspect	09/20/06 9:21:16 AM
Head Remote				
Emergency Light, Dual	10th South Corridor	02366748	Inspect	09/20/06 9:20:55 AM
Head Remote				
Emergency Light, Dual	10th West Stairwell	02366722	Inspect	09/20/06 8:35:04 AM
Head Remote				
Emergency Light, Dual	Penthouse East Stairwell	02366720	Inspect	09/20/06 8:24:53 AM
Head Remote				
Emergency Light, Dual	Penthouse North Corridor	02366746	Inspect	09/20/06 8:47:23 AM
Head Remote				
Emergency Light, Dual	Penthouse South Corridor	02366747	Inspect	09/20/06 8:48:16 AM
Head Remote				
Emergency Light, Dual	Penthouse West Stairwell	02366719	Inspect	09/20/06 8:11:35 AM
Head Remote				
Exit Sign, Self-Luminous	Basement East Stair	02366792	Inspect	09/21/06 4:07:26 PM
Exit Sign, Self-Luminous	Basement Inside Storeroom B01	02366823	Inspect	09/21/06 4:43:21 PM
Exit Sign, Self-Luminous	Basement Inside Storeroom B05	02366833	Inspect	09/21/06 4:47:36 PM
Exit Sign, Self-Luminous	Basement Inside Storeroom B55	02366834	Inspect	09/21/06 4:48:16 PM

Device Type	Location	ScanID : S/N	Service	Date Time
Exit Sign, Self-Luminous	Basement North Corridor	02366813	Inspect	09/21/06 4:38:17 PM
Exit Sign, Self-Luminous	Basement South Corridor	02366812	Inspect	09/21/06 4:38:08 PM
Exit Sign, Self-Luminous	Basement West Stair	02366793	Inspect	09/21/06 4:13:46 PM
Exit Sign, Self-Luminous	1st Main Lobby	02366835	Inspect	09/21/06 4:48:27 PM
Exit Sign, Self-Luminous	1st East Stair	02366791	Inspect	09/21/06 4:06:21 PM
Exit Sign, Self-Luminous	1st West Stair	02366790	Inspect	09/21/06 4:06:12 PM
Exit Sign, Self-Luminous	2nd East Stair	02366788	Inspect	09/21/06 4:05:29 PM
Exit Sign, Self-Luminous	2nd Inside Suite 201	02366822	Inspect	09/21/06 4:43:06 PM
Exit Sign, Self-Luminous	2nd Inside Suite 211	02366832	Inspect	09/21/06 4:47:12 PM
Exit Sign, Self-Luminous	2nd North Corridor	02366810	Inspect	09/21/06 4:37:28 PM
Exit Sign, Self-Luminous	2nd South Corridor	02366811	Inspect	09/21/06 4:37:39 PM
Exit Sign, Self-Luminous	2nd West Stair	02366789	Inspect	09/21/06 4:05:39 PM
Exit Sign, Self-Luminous	3rd East Stair	02366787	Inspect	09/21/06 4:05:20 PM
Exit Sign, Self-Luminous	3rd Inside Suite 301	02366821	Inspect	09/21/06 4:42:48 PM
Exit Sign, Self-Luminous	3rd Inside Suite 333	02366831	Inspect	09/21/06 4:46:44 PM
Exit Sign, Self-Luminous	3rd North Corridor	02366809	Inspect	09/21/06 4:37:14 PM
Exit Sign, Self-Luminous	3rd South Corridor	02366808	Inspect	09/21/06 4:37:05 PM
Exit Sign, Self-Luminous	3rd West Stair	02366786	Inspect	09/21/06 4:05:11 PM
Exit Sign, Self-Luminous	4th East Stair	02366784	Inspect	09/21/06 4:03:09 PM
Exit Sign, Self-Luminous	4th Inside Suite 401	02366820	Inspect	09/21/06 4:42:38 PM
Exit Sign, Self-Luminous	4th Inside Suite 415	02366830	Inspect	09/21/06 4:46:31 PM
Exit Sign, Self-Luminous	4th North Corridor	02366806	Inspect	09/21/06 4:36:39 PM
Exit Sign, Self-Luminous	4th South Corridor	02366807	Inspect	09/21/06 4:36:49 PM
Exit Sign, Self-Luminous	4th West Stair	02366785	Inspect	09/21/06 4:04:53 PM
Exit Sign, Self-Luminous	5th East Stair	02366783	Inspect	09/21/06 4:02:51 PM
Exit Sign, Self-Luminous	5th Inside Suite 501	02366819	Inspect	09/21/06 4:42:10 PM
Exit Sign, Self-Luminous	5th Inside Suite 515	02366829	Inspect	09/21/06 4:46:10 PM
Exit Sign, Self-Luminous	5th North Corridor	02366805	Inspect	09/21/06 4:36:28 PM
Exit Sign, Self-Luminous	5th South Corridor	02366804	Inspect	09/21/06 4:36:18 PM
Exit Sign, Self-Luminous	5th West Stair	02366782	Inspect	09/21/06 4:02:41 PM
Exit Sign, Self-Luminous	6th East Stair	02366780	Inspect	09/21/06 4:02:18 PM
Exit Sign, Self-Luminous	6th Inside Suite 601	02366818	Inspect	09/21/06 4:41:51 PM
Exit Sign, Self-Luminous	6th Inside Suite 636	02366828	Inspect	09/21/06 4:45:52 PM
Exit Sign, Self-Luminous	6th North Corridor	02366802	Inspect	09/21/06 4:35:57 PM
Exit Sign, Self-Luminous	6th South Corridor	02366803	Inspect	09/21/06 4:36:09 PM
Exit Sign, Self-Luminous	6th West Stair	02366781	Inspect	09/21/06 4:02:30 PM
Exit Sign, Self-Luminous	7th East Stair	02366779	Inspect	09/21/06 4:02:09 PM
Exit Sign, Self-Luminous	7th Inside Suite 701	02366817	Inspect	09/21/06 4:41:34 PM
Exit Sign, Self-Luminous	7th Inside Suite 736	02366827	Inspect	09/21/06 4:45:34 PM
Exit Sign, Self-Luminous	7th North Corridor	02366801	Inspect	09/21/06 4:24:43 PM
Exit Sign, Self-Luminous	7th South Corridor	02366800	Inspect	09/21/06 4:17:37 PM
Exit Sign, Self-Luminous	7th West Stair	02366778	Inspect	09/21/06 4:01:55 PM
Exit Sign, Self-Luminous	8th East Stair	02366776	Inspect	09/21/06 4:01:29 PM
Exit Sign, Self-Luminous	8th Inside Suite 801	02366816	Inspect	09/21/06 4:41:13 PM
Exit Sign, Self-Luminous	8th Inside Suite 827	02366826	Inspect	09/21/06 4:45:14 PM
Exit Sign, Self-Luminous	8th North Corridor	02366798	Inspect	09/21/06 4:17:17 PM
Exit Sign, Self-Luminous	8th South Corridor	02366799	Inspect	09/21/06 4:17:27 PM
Exit Sign, Self-Luminous	8th West Stair	02366777	Inspect	09/21/06 4:01:44 PM
Exit Sign, Self-Luminous	9th East Stair	02366775	Inspect	09/21/06 4:01:14 PM
Exit Sign, Self-Luminous	9th Inside Suite 901	02366815	Inspect	09/21/06 4:41:03 PM
Exit Sign, Self-Luminous	9th Inside Suite 925	02366825	Inspect	09/21/06 4:44:51 PM
Exit Sign, Self-Luminous	9th North Corridor	02366797	Inspect	09/21/06 4:17:07 PM



Device Type	Location	ScanID : S/N	Service	Date Time
Exit Sign, Self-Luminous	9th South Corridor	02366796	Inspect	09/21/06 4:16:56 PM
Exit Sign, Self-Luminous	9th West Stair	02366774	Inspect	09/21/06 4:01:01 PM
Exit Sign, Self-Luminous	10th East Stair	02366772	Inspect	09/21/06 8:43:59 AM
Exit Sign, Self-Luminous	10th Inside Suite 1001	02366814	Inspect	09/21/06 4:40:57 PM
Exit Sign, Self-Luminous	10th Inside Suite 1015	02366824	Inspect	09/21/06 4:44:18 PM
Exit Sign, Self-Luminous	10th North Corridor	02366794	Inspect	09/21/06 4:14:37 PM
Exit Sign, Self-Luminous	10th South Corridor	02366795	Inspect	09/21/06 4:16:45 AM
Exit Sign, Self-Luminous	10th West Stair	02366773	Inspect	09/21/06 4:00:39 PM
Exit Sign, Self-Luminous	Penthouse East Stair	02366770	Inspect	09/21/06 8:31:02 AM
Exit Sign, Self-Luminous	Penthouse West Stair	02366771	Inspect	09/21/06 8:37:03 AM
<b>Protective</b>				
Hearing Protection, Earplugs	Basement Central Mechanical Room	02366710	Inspect	09/21/06 9:16:13 AM
<b>Safety</b>				
Breathing Apparatus, 30 Min, Self-contained	1st Security Console	02366717 : 7261119	Inspect	09/20/06 7:39:50 AM
Defibrillator, Portable	1st Security Console	02366716 : 02349241	Inspect	09/20/06 7:34:39 AM
Eye Wash Station, Plumbed Wall Mounted	Basement Chiller Room	02366715	Inspect	09/20/06 7:34:12 AM
Eye Wash Station, Plumbed Wall Mounted	Penthouse Mechanical Room	02366714	Inspect	09/20/06 7:33:46 AM
Shower Station, Drench	Basement Chiller Room	02366712	Inspect	09/20/06 7:30:57 AM
Shower Station, Drench	Penthouse Mechanical Room	02366713	Inspect	09/20/06 7:32:03 AM
Spill Control, Absorbent	Basement Central Mechanical Room	02366711	Inspect	09/20/06 7:29:57 AM
<b>Failed/Other</b>				
<b>Fire</b>				
Fire Extinguisher, 10 Lbs, A.B.C	Basement Employee Break Room	02366848 : MT-049409	Inspect	09/21/06 8:36:54 AM
Fire Extinguisher, 10 Lbs, A.B.C	Basement Spare	02365923 : HT-769874	Inspect	09/21/06 1:19:46 PM
Fire Extinguisher, 10 Lbs, A.B.C	Basement Spare	02365977 : KT-271827	Hydro Test	09/21/06 2:26:08 PM
Fire Extinguisher, 10 Lbs, A.B.C	Basement Spare	02366844 : KZ-00923466	Inspect	09/21/06 2:38:00 PM
Fire Extinguisher, 10 Lbs, A.B.C	Basement Spare	02366845 : KK-00923440	Inspect	09/21/06 2:40:23 PM
Fire Extinguisher, 10 Lbs, A.B.C	Basement Spare	02366846 : KK-00923444	Inspect	09/21/06 2:41:39 PM
Fire Extinguisher, 10 Lbs, A.B.C	Basement Spare	02365961 : KZ-00923439	Inspect	09/21/06 3:44:15 PM
Fire Extinguisher, 10 Lbs, A.B.C	Basement Spare	02365976 : MT-049407	Inspect	09/21/06 3:59:38 PM
Fire Extinguisher, 10 Lbs, A.B.C	Basement Central Mechanical Room	02365916 : LW-770550	Hydro Test	09/21/06 2:29:15 PM
Fire Extinguisher, 10 Lbs, A.B.C	Basement Central Mechanical Room	02366836 : LW-770551	Hydro Test	09/21/06 2:29:40 PM
Fire Extinguisher, 10 Lbs, A.B.C	Basement Central Mechanical Room	02366837 : LW-770551	Hydro Test	09/21/06 2:29:57 PM

Device Type	Location	ScanID : S/N	Service	Date Time
Fire Extinguisher, 10 Lbs, A.B.C	Basement Central Mechanical Room	02366838 : KW-770552	Hydro Test	09/21/06 2:30:28 PM
Fire Extinguisher, 10 Lbs, A.B.C	Basement Central Mechanical Room	02366841 : MR-770589	Hydro Test	09/21/06 2:33:07 PM
Fire Extinguisher, 10 Lbs, A.B.C	Basement Central Mechanical Room	02366840 : MW-770577	Hydro Test	09/21/06 3:42:59 PM
Fire Extinguisher, 10 Lbs, A.B.C	Basement Central Mechanical Room	02366839 : KW-770572	Hydro Test	09/21/06 3:43:55 PM
Fire Extinguisher, 10 Lbs, A.B.C	Basement Central Mechanical Room	02366842 : MZ-900554	Hydro Test	09/21/06 3:44:05 PM
Fire Extinguisher, 10 Lbs, A.B.C	1st Behind Security Desk	02366847 : MT-049408	Inspect	09/21/06 8:35:00 AM
Fire Extinguisher, 10 Lbs, A.B.C	2nd North Elevator Lobby	02365966 : GJ-417298	6yr Maintenance	09/21/06 1:20:31 PM
Fire Extinguisher, 10 Lbs, A.B.C	2nd South Elevator Lobby	02365967 : GE-711140	6yr Maintenance	09/21/06 1:20:45 PM
Fire Extinguisher, 10 Lbs, A.B.C	3rd Atrium Hallway	02365963 : RC-364872	6yr Maintenance	09/21/06 1:21:22 PM
Fire Extinguisher, 10 Lbs, A.B.C	3rd Cafeteria	02365962 : KW-545910	Hydro Test	09/21/06 1:21:12 PM
Fire Extinguisher, 10 Lbs, A.B.C	4th Audio/Visual Storeroom	02365973 : HA-566215	6yr Maintenance	09/21/06 3:41:48 PM
Fire Extinguisher, 10 Lbs, A.B.C	4th Hallway Break Area	02365974 : FV-120167	6yr Maintenance	09/21/06 3:42:10 PM
Fire Extinguisher, 10 Lbs, A.B.C	7th West Hallway	02366002 : HT-768248	Breakdown	09/21/06 8:23:41 AM
Fire Extinguisher, 10 Lbs, A.B.C	10th West Hallway	02365957 : GJ-417271	6yr Maintenance	09/21/06 3:42:19 PM
Fire Extinguisher, 10 Lbs, A.B.C	Penthouse Elevator Equipment Room	02365956 : BZ-956368	6yr Maintenance	09/21/06 3:16:33 PM

# Fire Extinguisher Maintenance Report

Generated by: [BuildingReports.com](http://BuildingReports.com)

Building: Sample Building Report					
<p><i>This report provides details on the Hydrostatic Test and Maintenance/Breakdown dates for fire extinguishers. Items that will need either of these services at any time in the next two years are displayed. Items that are "Due this year" or "Due Next Year" are shown grouped together for budgeting purposes.</i></p>					
ScanID	Location	Serial #	Hydro	Serviced	Mfr Date
<b><i>Due This Year</i></b>					
<b>Breakdown/Maintenance</b>					
<b>Fire Extinguisher, A.B.C, 10 Lbs</b>					
02366840	Basement Central Mechanical Room	MW-770577	12/31/06	01/01/01	01/01/95
02366002	7th West Hallway	HT-768248	12/31/06	01/01/01	01/01/95
02365921	Basement Fire Control Center	MZ-595183	12/31/06	01/01/01	01/01/95
02365919	Basement Emergency Generator Room	EF-098174	12/31/06	01/01/01	01/01/95
<b>Hydrostatic Test</b>					
02365918	Basement Telephone/Electrical Room	NM-451726	12/31/06	01/01/14	01/01/96
02365973	4th Audio/Visual Storeroom	HA-566215	12/31/06	01/01/14	01/01/96
02365974	4th Hallway Break Area	FV-120167	12/31/06	01/01/14	01/01/96
02365957	10th West Hallway	GJ-417271	12/31/06	01/01/14	01/01/96
02366840	Basement Central Mechanical Room	MW-770577	12/31/06	01/01/01	01/01/95
02366002	7th West Hallway	HT-768248	12/31/06	01/01/01	01/01/95
02365921	Basement Fire Control Center	MZ-595183	12/31/06	01/01/01	01/01/95
02365919	Basement Emergency Generator Room	EF-098174	12/31/06	01/01/01	01/01/95
<b><i>Due Next Year</i></b>					
<b>Breakdown/Maintenance</b>					
<b>Fire Extinguisher, A.B.C, 10 Lbs</b>					
02365976	Basement Spare	MT-049407	12/31/07	01/01/01	01/01/95
02366847	1st Behind Security Desk	MT-049408	12/31/07	01/01/01	01/01/95
02366848	Basement Employee Break Room	MT-049409	12/31/07	01/01/01	01/01/95
<b>Hydrostatic Test</b>					
02365922	Basement Fire Control Center	NC-595067	12/31/07	01/01/13	01/01/95
02365975	1st Bank Entrance	ET-264732	12/31/07	01/01/13	01/01/95
02365976	Basement Spare	MT-049407	12/31/07	01/01/01	01/01/95
02365917	Basement Central Mechanical Room	MR-917697	12/31/07	01/01/13	01/01/95
02366847	1st Behind Security Desk	MT-049408	12/31/07	01/01/01	01/01/95
02366848	Basement Employee Break Room	MT-049409	12/31/07	01/01/01	01/01/95
<b><i>Due in 2008</i></b>					
<b>Breakdown/Maintenance</b>					
<b>Fire Extinguisher, A.B.C, 10 Lbs</b>					
02366839	Basement Central Mechanical Room	KW-770572	12/31/08	01/01/01	01/01/95
02366842	Basement Central Mechanical Room	MZ-900554	12/31/08	01/01/01	01/01/95
02365961	Basement Spare	KZ-00923439	12/31/08	01/01/01	01/01/95
<b>Hydrostatic Test</b>					
02365956	Penthouse Elevator Equipment Room	BZ-956368	12/31/08	01/01/14	01/01/96

ScanID	Location	Serial #	Hydro	Serviced	Mfr Date
02366839	Basement Central Mechanical Room	KW-770572	12/31/08	01/01/01	01/01/95
02366842	Basement Central Mechanical Room	MZ-900554	12/31/08	01/01/01	01/01/95
02365961	Basement Spare	KZ-00923439	12/31/08	01/01/01	01/01/95

# Fire Hose Maintenance Report

Generated by: *BuildingReports.com*

Building: Sample Building Report					
<p><i>This report provides details on the Hydrostatic Test dates for fire hose. Items that will need this service at any time in the next two years are displayed. Items that are "Due this year" or "Due Next Year" are shown grouped together for budgeting purposes.</i></p>					
ScanID	Location	Serial #	Hydro	Serviced	Mfr Date
<b>Due in 2008</b>					
<b>Hydrostatic Test</b>					
<b>Fire Hose, Dual Jacket, 50 ft</b>					
02366661	Penthouse East Hallway		12/31/05	01/01/11	11/03/00
02366662	Penthouse West Hallway		12/31/05	01/01/11	11/03/00
02366663	10th West Hallway		12/31/05	01/01/11	11/03/00
02366664	10th East Hallway		12/31/05	01/01/11	11/03/00
02366665	9th East Hallway		12/31/05	01/01/11	11/03/00
02366666	9th West Hallway		12/31/05	01/01/11	11/03/00
02366667	8th West Hallway		12/31/05	01/01/11	11/03/00
02366668	8th East Hallway		12/31/05	01/01/11	11/03/00
02366669	7th East Hallway		12/31/05	01/01/11	11/03/00
02366670	7th West Hallway		12/31/05	01/01/11	11/03/00
02366671	6th West Hallway		12/31/05	01/01/11	11/03/00
02366672	6th East Hallway		12/31/05	01/01/11	11/03/00
02366673	5th East Hallway		12/31/05	01/01/11	11/03/00
02366674	5th West Hallway		12/31/05	01/01/11	11/03/00
02366675	4th West Hallway		12/31/05	01/01/11	11/03/00
02366676	4th East Hallway		12/31/05	01/01/11	11/03/00
02366677	3rd East Hallway		12/31/05	01/01/11	11/03/00
02366679	2nd East Hallway		12/31/05	01/01/11	11/03/00
02366680	2nd West Hallway		12/31/05	01/01/11	11/03/00
02366681	1st West Hallway		12/31/05	01/01/11	11/03/00
02366682	1st East Hallway		12/31/05	01/01/11	11/03/00
02366683	Basement East Hallway		12/31/05	01/01/11	11/03/00
02366684	Basement West Hallway		12/31/05	01/01/11	11/03/00
02366678	3rd West Hallway		12/31/05	01/01/11	11/03/00

# Exit/Emergency Lighting

Generated by: BuildingReports.com

## Building: Sample Building Report

*Exit and Emergency Lighting items are listed with each of the relevant measurements for pre and post test voltages, the load current, charge rate, and the rated voltage and current capacity of standby batteries. The remote heads indicate the number of other items that get their supply voltage from this item. Items are listed by type, and grouped by Passed or Failed/Other.*

Location	Model #	Post Chk	Rated Volts	Pre-Test Volts	Post-Test Volts	Load Amps	Charge Amps	Remote Heads	Amp Hours
<b><i>Passed</i></b>									
<b>Emergency Light, Dual Head Remote</b>									
Basement East Stairwell	2300	<input type="checkbox"/>	6	6	6	10	10	2	10
Basement West Stairwell	2300	<input type="checkbox"/>	6	6	6	10	10	2	10
Basement Loading Dock	2300	<input type="checkbox"/>	6	6	6	10	10	2	10
Basement Chiller Room	2300	<input type="checkbox"/>	6	6	6	10	10	2	10
Basement Generator Area	2300	<input type="checkbox"/>	6	6	6	10	10	2	10
Basement South Lobby	2300	<input type="checkbox"/>	6	6	6	10	10	2	10
Basement North Lobby	2300	<input type="checkbox"/>	6	6	6	10	10	2	10
1st West Stairwell	2300	<input type="checkbox"/>	6	6	6	10	10	2	10
1st East Stairwell	2300	<input type="checkbox"/>	6	6	6	10	10	2	10
1st North Lobby	2300	<input type="checkbox"/>	6	6	6	10	10	2	10
1st South Lobby	2300	<input type="checkbox"/>	6	6	6	10	10	2	10
2nd East Stairwell	2300	<input type="checkbox"/>	6	6	6	10	10	2	10
2nd West Stairwell	2300	<input type="checkbox"/>	6	6	6	10	10	2	10
2nd South Corridor	2300	<input type="checkbox"/>	6	6	6	10	10	2	10
2nd North Corridor	2300	<input type="checkbox"/>	6	6	6	10	10	2	10
3rd West Stairwell	2300	<input type="checkbox"/>	6	6	6	10	10	2	10
3rd East Stairwell	2300	<input type="checkbox"/>	6	6	6	10	10	2	10
3rd North Corridor	2300	<input type="checkbox"/>	6	6	6	10	10	2	10
3rd South Corridor	2300	<input type="checkbox"/>	6	6	6	10	10	2	10
4th East Stairwell	2300	<input type="checkbox"/>	6	6	6	10	10	2	10
4th West Stairwell	2300	<input type="checkbox"/>	6	6	6	10	10	2	10
4th South Corridor	2300	<input type="checkbox"/>	6	6	6	10	10	2	10
4th North Corridor	2300	<input type="checkbox"/>	6	6	6	10	10	2	10
5th West Stairwell	2300	<input type="checkbox"/>	6	6	6	10	10	2	10
5th East Stairwell	2300	<input type="checkbox"/>	6	6	6	10	10	2	10
5th North Corridor	2300	<input type="checkbox"/>	6	6	6	10	10	2	10
5th South Corridor	2300	<input type="checkbox"/>	6	6	6	10	10	2	10
6th East Stairwell	2300	<input type="checkbox"/>	6	6	6	10	10	2	10
6th West Stairwell	2300	<input type="checkbox"/>	6	6	6	10	10	2	10
6th South Corridor	2300	<input type="checkbox"/>	6	6	6	10	10	2	10
6th North Corridor	2300	<input type="checkbox"/>	6	6	6	10	10	2	10
7th West Stairwell	2300	<input type="checkbox"/>	6	6	6	10	10	2	10
7th East Stairwell	2300	<input type="checkbox"/>	6	6	6	10	10	2	10
7th North Corridor	2300	<input type="checkbox"/>	6	6	6	10	10	2	10
7th South Corridor	2300	<input type="checkbox"/>	6	6	6	10	10	2	10
8th East Stairwell	2300	<input type="checkbox"/>	6	6	6	10	10	2	10
8th West Stairwell	2300	<input type="checkbox"/>	6	6	6	10	10	2	10

			Rated	Pre-Test	Post-Test	Load	Charge	Remote	Amp
8th South Corridor	2300	<input type="checkbox"/>	6	6	6	10	10	2	10
8th North Corridor	2300	<input type="checkbox"/>	6	6	6	10	10	2	10
9th West Stairwell	2300	<input type="checkbox"/>	6	6	6	10	10	2	10
9th East Stairwell	2300	<input type="checkbox"/>	6	6	6	10	10	2	10
9th North Corridor	2300	<input type="checkbox"/>	6	6	6	10	10	2	10
9th South Corridor	2300	<input type="checkbox"/>	6	6	6	10	10	2	10
10th East Stairwell	2300	<input type="checkbox"/>	6	6	6	10	10	2	10
10th West Stairwell	2300	<input type="checkbox"/>	6	6	6	10	10	2	10
10th South Corridor	2300	<input type="checkbox"/>	6	6	6	10	10	2	10
10th North Corridor	2300	<input type="checkbox"/>	6	6	6	10	10	2	10
Penthouse West Stairwell	2300	<input type="checkbox"/>	6	6	6	10	10	2	10
Penthouse East Stairwell	2300	<input type="checkbox"/>	6	6	6	10	10	2	10
Penthouse North Corridor	2300	<input type="checkbox"/>	6	6	6	10	10	2	10
Penthouse South Corridor	2300	<input type="checkbox"/>	6	6	6	10	10	2	10
<b>Exit Sign, Self-Luminous</b>									
Basement East Stair	X61	<input type="checkbox"/>	4	4	4	8	8		10
Basement West Stair	X61	<input type="checkbox"/>	4	4	4	8	8		10
Basement South Corridor	X61	<input type="checkbox"/>	4	4	4	8	8		10
Basement North Corridor	X61	<input type="checkbox"/>	4	4	4	8	8		10
Basement Inside Storeroom B01	X61	<input type="checkbox"/>	4	4	4	8	8		10
Basement Inside Storeroom B05	X61	<input type="checkbox"/>	4	4	4	8	8		10
Basement Inside Storeroom B55	X61	<input type="checkbox"/>	4	4	4	8	8		10
1st West Stair	X61	<input type="checkbox"/>	4	4	4	8	8		10
1st East Stair	X61	<input type="checkbox"/>	4	4	4	8	8		10
1st Main Lobby	X61	<input type="checkbox"/>	4	4	4	8	8		10
2nd East Stair	X61	<input type="checkbox"/>	4	4	4	8	8		10
2nd West Stair	X61	<input type="checkbox"/>	4	4	4	8	8		10
2nd North Corridor	X61	<input checked="" type="checkbox"/>	4	4	4	8	8		10
2nd South Corridor	X61	<input type="checkbox"/>	4	4	4	8	8		10
2nd Inside Suite 201	X61	<input type="checkbox"/>	4	4	4	8	8		10
2nd Inside Suite 211	X61	<input type="checkbox"/>	4	4	4	8	8		10
3rd West Stair	X61	<input type="checkbox"/>	4	4	4	8	8		10
3rd East Stair	X61	<input type="checkbox"/>	4	4	4	8	8		10
3rd South Corridor	X61	<input type="checkbox"/>	4	4	4	8	8		10
3rd North Corridor	X61	<input type="checkbox"/>	4	4	4	8	8		10
3rd Inside Suite 301	X61	<input type="checkbox"/>	4	4	4	8	8		10
3rd Inside Suite 333	X61	<input type="checkbox"/>	4	4	4	8	8		10
4th East Stair	X61	<input type="checkbox"/>	4	4	4	8	8		10
4th West Stair	X61	<input type="checkbox"/>	4	4	4	8	8		10
4th North Corridor	X61	<input type="checkbox"/>	4	4	4	8	8		10
4th South Corridor	X61	<input type="checkbox"/>	4	4	4	8	8		10
4th Inside Suite 401	X61	<input type="checkbox"/>	4	4	4	8	8		10
4th Inside Suite 415	X61	<input type="checkbox"/>	4	4	4	8	8		10
5th West Stair	X61	<input type="checkbox"/>	4	4	4	8	8		10
5th East Stair	X61	<input type="checkbox"/>	4	4	4	8	8		10
5th South Corridor	X61	<input type="checkbox"/>	4	4	4	8	8		10
5th North Corridor	X61	<input type="checkbox"/>	4	4	4	8	8		10
5th Inside Suite 501	X61	<input checked="" type="checkbox"/>	4	4	4	8	8		10
5th Inside Suite 515	X61	<input type="checkbox"/>	4	4	4	8	8		10
6th East Stair	X61	<input type="checkbox"/>	4	4	4	8	8		10
6th West Stair	X61	<input type="checkbox"/>	4	4	4	8	8		10
6th North Corridor	X61	<input type="checkbox"/>	4	4	4	8	8		10

			Rated	Pre-Test	Post-Test	Load	Charge	Remote	Amp
6th South Corridor	X61	<input type="checkbox"/>	4	4	4	8	8		10
6th Inside Suite 601	X61	<input type="checkbox"/>	4	4	4	8	8		10
6th Inside Suite 636	X61	<input type="checkbox"/>	4	4	4	8	8		10
7th West Stair	X61	<input type="checkbox"/>	4	4	4	8	8		10
7th East Stair	X61	<input type="checkbox"/>	4	4	4	8	8		10
7th South Corridor	X61	<input type="checkbox"/>	4	4	4	8	8		10
7th North Corridor	X61	<input type="checkbox"/>	4	4	4	8	8		10
7th Inside Suite 701	X61	<input type="checkbox"/>	4	4	4	8	8		10
7th Inside Suite 736	X61	<input type="checkbox"/>	4	4	4	8	8		10
8th East Stair	X61	<input type="checkbox"/>	4	4	4	8	8		10
8th West Stair	X61	<input type="checkbox"/>	4	4	4	8	8		10
8th North Corridor	X61	<input type="checkbox"/>	4	4	4	8	8		10
8th South Corridor	X61	<input type="checkbox"/>	4	4	4	8	8		10
8th Inside Suite 801	X61	<input type="checkbox"/>	4	4	4	8	8		10
8th Inside Suite 827	X61	<input type="checkbox"/>	4	4	4	8	8		10
9th West Stair	X61	<input type="checkbox"/>	4	4	4	8	8		10
9th East Stair	X61	<input type="checkbox"/>	4	4	4	8	8		10
9th South Corridor	X61	<input type="checkbox"/>	4	4	4	8	8		10
9th North Corridor	X61	<input type="checkbox"/>	4	4	4	8	8		10
9th Inside Suite 901	X61	<input type="checkbox"/>	4	4	4	8	8		10
9th Inside Suite 925	X61	<input type="checkbox"/>	4	4	4	8	8		10
10th East Stair	X61	<input type="checkbox"/>	4	4	4	8	8		10
10th West Stair	X61	<input type="checkbox"/>	4	4	4	8	8		10
10th North Corridor	X61	<input type="checkbox"/>	4	4	4	8	8		10
10th South Corridor	X61	<input type="checkbox"/>	4	4	4	8	8		10
10th Inside Suite 1001	X61	<input type="checkbox"/>	4	4	4	8	8		10
10th Inside Suite 1015	X61	<input type="checkbox"/>	4	4	4	8	8		10
Penthouse East Stair	X61	<input type="checkbox"/>	4	4	4	8	8		10
Penthouse West Stair	X61	<input type="checkbox"/>	4	4	4	8	8		10



# Standby and Emergency Power Report

Generated by: *BuildingReports.com*

Building: Sample Building Report							
<i>The Standby and Emergency Power Report details the test measurements for Batteries, Emergency Generators, Emergency Power Systems, and other items that provide emergency or standby power support. Items are listed by type, and Grouped by Passed or Failed/Other.</i>							
		Rated	Pre-Test	Post-Test	Load	Charge	Amp
Type	Location	Volts	Volts	Volts	Amps	Amps	Hours
<b><i>Passed</i></b>							
<b>Emergency Generator</b>							
Diesel	Basement Outside Chiller Room	480					752

# Equipment Report

Generated by: [BuildingReports.com](http://BuildingReports.com)

## Building: Sample Building Report

*The Equipment Report details the test and inspections of various safety equipment, fire doors, fire dampers, cooking equipment and other miscellaneous items requiring inspection by security guards, building staff, or other routine check list type items. Each item is listed by type, and grouped by Passed or Failed/Other.*

Type	Location	Manufacturer	Model #	ScanID
<b><i>Passed</i></b>				
<b>Fire Damper</b>				
Smoke	Basement Central Mechanical Room	Air Systems	DH5498	02366601
Smoke	Basement Elevator Pit	Air Systems	DH5498	02366624
Smoke	1st Mechanical Room	Air Systems	DH5498	02366612
Smoke	1st Elevator Shaft	Air Systems	DH5498	02366623
Smoke	2nd Mechanical Room	Air Systems	DH5498	02366611
Smoke	2nd Elevator Shaft	Air Systems	DH5498	02366622
Smoke	3rd Mechanical Room	Air Systems	DH5498	02366610
Smoke	3rd Elevator Shaft	Air Systems	DH5498	02366621
Smoke	4th Mechanical Room	Air Systems	DH5498	02366609
Smoke	4th Elevator Shaft	Air Systems	DH5498	02366620
Smoke	5th Mechanical Room	Air Systems	DH5498	02366608
Smoke	5th Elevator Shaft	Air Systems	DH5498	02366619
Smoke	6th Mechanical Room	Air Systems	DH5498	02366607
Smoke	6th Elevator Shaft	Air Systems	DH5498	02366618
Smoke	7th Mechanical Room	Air Systems	DH5498	02366606
Smoke	7th Elevator Shaft	Air Systems	DH5498	02366617
Smoke	8th Mechanical Room	Air Systems	DH5498	02366605
Smoke	8th Elevator Shaft	Air Systems	DH5498	02366616
Smoke	9th Mechanical Room	Air Systems	DH5498	02366604
Smoke	9th Elevator Shaft	Air Systems	DH5498	02366615
Smoke	10th Mechanical Room	Air Systems	DH5498	02366603
Smoke	10th Elevator Shaft	Air Systems	DH5498	02366614
Smoke	Penthouse Mechanical Room	Air Systems	DH5498	02366602
Smoke	Penthouse Elevator Shaft	Air Systems	DH5498	02366613
<b>Fire Door</b>				
Automatic Closing	Basement West Elevator Lobby	Peachtree	SCD111	02366639
Automatic Closing	Basement East Elevator Lobby	Peachtree	SCD111	02366640
Automatic Closing	4th East Elevator Lobby	Peachtree	SCD111	02366637
Automatic Closing	4th West Elevator Lobby	Peachtree	SCD111	02366638
Automatic Closing	5th West Elevator Lobby	Peachtree	SCD111	02366635
Automatic Closing	5th East Elevator Lobby	Peachtree	SCD111	02366636
Automatic Closing	6th East Elevator Lobby	Peachtree	SCD111	02366633
Automatic Closing	6th West Elevator Lobby	Peachtree	SCD111	02366634
Automatic Closing	7th West Elevator Lobby	Peachtree	SCD111	02366631
Automatic Closing	7th East Elevator Lobby	Peachtree	SCD111	02366632
Automatic Closing	8th East Elevator Lobby	Peachtree	SCD111	02366629
Automatic Closing	8th West Elevator Lobby	Peachtree	SCD111	02366630
Automatic Closing	9th West Elevator Lobby	Peachtree	SCD111	02366627

Type	Location	Manufacturer	Model #	ScanID
Automatic Closing	9th East Elevator Lobby	Peachtree	SCD111	02366628
Automatic Closing	10th East Elevator Lobby	Peachtree	SCD111	02366625
Automatic Closing	10th West Elevator Lobby	Peachtree	SCD111	02366626

# Personal Protective Equipment Report

Generated by: *BuildingReports.com*

Building: Sample Building Report				
<i>Personal Protective Equipment Report contains items such as eyewash stations, eye protection, hearing protection, clothing, personal armor or body protective gear, first aid, or other emergency use equipment. Items are listed by type, and grouped by Passed or Failed/Other.</i>				
Type	Location	Manufacturer	Model #	ScanID
<i>Passed</i>				
<b>Hearing Protection</b>				
Earplugs	Basement Central Mechanical Room	Doss	EP1213	02366710
<b>Defibrillator</b>				
Portable	1st Security Console	American	IHC	02366716
<b>Eye Wash Station</b>				
Plumbed Wall Mounted	Basement Chiller Room	Warehouse	EW11	02366715
Plumbed Wall Mounted	Penthouse Mechanical Room	Warehouse	EW11	02366714
<b>Shower Station</b>				
Drench	Basement Chiller Room	Warehouse	SS10	02366712
Drench	Penthouse Mechanical Room	Warehouse	SS10	02366713

# Respiratory Protection Report

Generated by: BuildingReports.com

Building: Sample Building Report				
<i>Respiratory Protection Report consolidates items such as breathing apparatus, breathing cylinders, respirators of all types, and canisters and filters for respiratory equipment. Items are listed by type and grouped by Passed or Failed/Other.</i>				
Location	Manufacturer	Model #	Serial #	ScanID
<i>Passed</i>				
<b>Breathing Apparatus, Self-contained, 30 Min</b>				
1st Security Console	American	BA073	7261119	02366717

# Storage/Containment Report

Generated by: BuildingReports.com

Building: Sample Building Report				
<i>The Storage/Containment Report list items that are usage for spill control and containment, and storage containers of all types of hazardous chemicals, petroleum products, and other special hazard storage items.</i>				
Type	Location	Manufacturer	Model #	ScanID
<i>Passed</i>				
<b>Spill Control</b>				
Absorbent	Basement Central Mechanical Room	Absorb-All	SL-022	02366711

# Inventory & Warranty Report

Generated by: BuildingReports.com

## Building: Sample Building Report

*The Inventory & Warranty Report lists each of the devices and items that are included in your Inspection Report. A complete inventory count by device type and category is provided. Items installed within the last 90 days, within the last year, and devices installed for two years or more are grouped together for easy reference.*

Device or Item	Category	% of Inventory	Quantity
Fire Extinguisher	Fire	30%	101
Fire Damper	Fire	7%	24
Fire Door	Fire	5%	16
Extinguisher Cabinet	Fire	6%	20
Fire Hose	Fire	7%	24
Fire Hose Cabinet	Fire	7%	24
Wheeled Unit	Fire	0%	1
Spill Control	Safety	0%	1
Shower Station	Safety	1%	2
Eye Wash Station	Safety	1%	2
Defibrillator	Safety	0%	1
Breathing Apparatus	Safety	0%	1
Emergency Light	Lighting	15%	51
Exit Sign	Lighting	20%	66
Hearing Protection	Protective	0%	1
Emergency Generator	Lighting	0%	1

Type	Qty	Model #	Description	Manufacture Date
<b><i>In Service - 1 Year to 2 Years</i></b>				
<b>Fyr-Fighter</b>				
Fire Hose Cabinet	22	FFC200	Dual Jacket	11/05/2004
Fire Hose Cabinet	2	FFC200		11/05/2004
Wheeled Unit	1			11/05/2004
<b>Buckeye</b>				
Fire Extinguisher	1	WC-6 LITER	Class K	04/01/2004
<b><i>In Service - 2 Years to 3 Years</i></b>				
<b>Ansul</b>				
Fire Extinguisher	1	SY-0515	A.B.C	01/01/2004
<b>Amerex</b>				
Fire Extinguisher	2	371	Halon	01/01/2004
<b>American</b>				
Breathing Apparatus	1	BA073	Self-contained	09/10/2003
<b>Cummins</b>				
Emergency Generator	1	680FDC3053AE W	Diesel	09/10/2003
<b>Emergi-Lite</b>				
Emergency Light	50	2300	Dual Head Remote	09/10/2003

Type	Qty	Model #	Description	Manufacture Date
Exit Sign	66	X61	Self-Luminous	09/10/2003
<b><i>In Service - 3 Years to 5 Years</i></b>				
<b>Amerex</b>				
Fire Extinguisher	2	441	A.B.C	01/01/2003
<b>Ansul</b>				
Fire Extinguisher	1	SY-1014	A.B.C	01/01/2003
<b><i>In Service - 5 Years to 10 Years</i></b>				
<b>Buckeye</b>				
Fire Extinguisher	1	10HI SA80 ABC	A.B.C	01/01/2001
<b>Fyr-Fighter</b>				
Fire Hose	24	FF251	Dual Jacket	11/03/2000
<b>Amerex</b>				
Fire Extinguisher	1	500	A.B.C	01/01/2000
Fire Extinguisher	56	456	A.B.C	01/01/2000
Fire Extinguisher	1	B456-00	A.B.C.	01/01/2000
Fire Extinguisher	2	456	A.B.C	01/01/1999
Fire Extinguisher	1	A456-99	A.B.C	01/01/1999
Fire Extinguisher	1	B456-00	A.B.C.	01/01/1999
Fire Extinguisher	2	456	A.B.C	01/01/1998
<b><i>In Service - 10 Years to 15 Years</i></b>				
<b>Amerex</b>				
Fire Extinguisher	1	421	A.B.C	01/01/1996
Fire Extinguisher	3	456	A.B.C	01/01/1996
Fire Extinguisher	1	A456-96	A.B.C	01/01/1996
Fire Extinguisher	1	441	A.B.C	01/01/1995
Fire Extinguisher	1	456	A.B.C	01/01/1995
Fire Extinguisher	3	A456-93	A.B.C	01/01/1995
Fire Extinguisher	3	A456-95	A.B.C	01/01/1995
<b>Ansul</b>				
Fire Extinguisher	1	SY1014	A.B.C	01/01/1995
<b>Kidde</b>				
Fire Extinguisher	3	FA 460 HD-2	A.B.C	01/01/1995
<b>Pyrene</b>				
Fire Extinguisher	1	P10M	A.B.C	01/01/1995
<b>Ansul</b>				
Fire Extinguisher	3	SY1014	A.B.C	01/01/1994
Fire Extinguisher	1	SY-1014	A.B.C	04/01/1993
<b>American</b>				
Defibrillator	1	IHC	Portable	01/06/1993
<b>Cabinet King</b>				
Extinguisher Cabinet	1	FE143		01/01/1993
<b>Peachtree</b>				



Type	Qty	Model #	Description	Manufacture Date
Extinguisher Cabinet	19	FE143		01/01/1993
<b>Warehouse</b>				
Eye Wash Station	2	EW11	Plumbed Wall Mounted	01/01/1993
<b>Air Systems</b>				
Fire Damper	24	DH5498	Smoke	01/01/1993
<b>Peachtree</b>				
Fire Door	16	SCD111	Automatic Closing	01/01/1993
<b>Amerex</b>				
Fire Extinguisher	1	456	A.B.C	01/01/1993
Fire Extinguisher	5	A456-93	A.B.C	01/01/1993
<b>Doss</b>				
Hearing Protection	1	EP1213	Earplugs	01/01/1993
<b>Warehouse</b>				
Shower Station	2	SS10	Drench	01/01/1993
<b>Absorb-All</b>				
Spill Control	1	SL-022	Absorbent	01/01/1993
<b><i>In Service - 15 Years to 25 Years</i></b>				
<b>Emergi-Lite</b>				
Emergency Light	1	2300	Dual Head Remote	09/18/1986
<b><i>In Service - 25 Years or Older</i></b>				
<b>Amerex</b>				
Fire Extinguisher	1	456	A.B.C	10/11/1967